

Certificate of Disinfection

Certificate No:

Standard of Procedure: PD855468:2015

pH: 7.2

Kill Time: 01:00:00

Disinfection Used: Supercil

Dose ppm: 150

Post CL2 ppm: <5

Date: 01 Feb 2023

Customer: Lee Garry

Site: Harbour House
Harbour House, Portway, Ashton-on-Ribble,
Preston

Engineer: Simon McGing

Details of Work Carried Out: Cleaned and disinfected 2 x GRP water tanks in
plant room

Condition on Completion: Clean



Martin Lea
Operations Director

BrodexTrident South West
Queensgate House,
48 Queen Street,
Exeter, EX4 3SR
T: E:info@brodextrident.com

BrodexTrident 
COMPLIANCE SERVICES